



Notes:

- | | |
|--|-------------------------|
| 1. Creepage Distance | 11-1/2" (292mm) Min. |
| 2. Mechanical & Electrical Strength | 20000lbs (89kN) |
| 3. Mechanical Impact Strength | 90 Inch-Pounds (10 N-m) |
| 4. Tension Proof | 10000lbs (45kN) |
| 5. Low-Frequency Flashover Voltage (Dry) | 80kV |
| 6. Low-Frequency Flashover Voltage (Wet) | 50kV |
| 7. Critical Impulse Flashover Voltage (Positive) | 125kV |
| 8. Critical Impulse Flashover Voltage (Negative) | 130kV |
| 9. Low-Frequency Puncture Voltage | 110kV |
| 10. Low-Frequency Test Voltage, Rms to Ground | 10kV |
| 11. Color: Brown | |
| 12. Applicable Standard ANSI C29.2-1992. | |

General Tolerance			<p style="text-align: center;">DP 52-4 CLEVIS TRANSMISSION INSULATOR (ANSI 52-4 M&E 90kN)</p> <p style="text-align: center;">DULHUNTY POWER</p>				
<30	±1.5	ANGLE: ±		Mass	6kg	Scale	N/S
>30	±5%			A4-6231	REV	A	
Drawn	David Shao	Feb.27,2007					
Checked	JOE YUNG	Feb.27,2007					
Approved							