



Notes:

- | | |
|--|--------------------------|
| 1. Creepage Distance | 6-3/4" (171mm) |
| 2. Mechanical & Electrical Strength | 10000lbs(44kN) |
| 3. Mechanical Impact Strength | 45 Inch-Pounds, (50 N-m) |
| 4. Tension Proof | 5000lbs(22kN) |
| 5. Low-Frequency Flashover Voltage (Dry) | 60kV |
| 6. Low-Frequency Flashover Voltage (Wet) | 30kV |
| 7. Critical Impulse Flashover Voltage (Positive) | 100kV |
| 8. Critical Impulse Flashover Voltage (Negative) | 90kV |
| 9. Low-Frequency Puncture Voltage | 80kV |
| 10 Low-Frequency Test Voltage, Rms to Ground | 7.5kV |
| 11. Applicable standard ANSI C29.2-1992 | |

General Tolerance			DP 52-9-B DISTRIBUTION INSULATOR (ANSI 52-9-B)				
<30	± 1.5	ANGLE: ±					
>30	± 5%						
Drawn	DAZON SHAO	March 17, 2005	DULHUNTY POWER	Mass	3.0kg	Scale	N/S
Checked	JOE YUNG	March 17, 2005		A4-8261		REV	A
Approved	JACK ROUGHAN	March 17, 2005					