



NOTE:

- | | |
|---|-----------------|
| 1. Transverse Strength | 6000lbs(26.7kN) |
| 2. Low Frequency Flashover (Dry) | 35kV |
| 3. Vertical Low Frequency Flashover (Wet) | 18kV |
| 4. Horizontal Low Frequency Flashover (Wet) | 25kV |
| 5. Applicable Standard ANSI C29.3-1986. | |

General Tolerance			DP 53-5 SPOOL INSULATOR (ANSI 53-5)				
<30 mm	± 1.5 mm	ANGLE:					
>30 mm	$\pm 5\%$						
Drawn	William	Dec.28,2005	DULHUNTY POWER	Mass		Scale	N/S
Checked				A4-6095	REV		A
Approved							