


MONTH, YEAR
CHINA

NOTE:

- | | |
|--|--------------------|
| 1. Creepage Distance | 14" (356MM) MIN |
| 2. Dry Arcing Distance | 6.5" (165MM) MIN |
| 3. Cantilever Strength | 2800lbs (12.5kN) |
| 4. Low Frequency Flashover Voltage (Dry) | 70kV MIN |
| 5. Low Frequency Flashover Voltage (Wet) | 50kV |
| 6. Positive Critical Impulse Flashover | 120kV |
| 7. Radio Influence Voltage at 15kV | 100 microvolts MAX |
| 8. Applicable Standard ANSI C29.7-1996. | |

GENERAL TOLERANCE			DP 57-1 LINE POST INSULATOR (ANSI 57-1)					
<30	±1.5	ANGLE:						
>30	±5%							
Drawn	David Shao	Feb.3,2005	DULHUNTY POWER		Mass	5.2kg	Scale	
Verified					A4-8188	REV	B	
Approved								