


  
 MONTH, YEAR  
 CHINA

NOTE:

- |  |                   |
|--|-------------------|
| 1. Creepage Distance                     | 15" (381MM) MIN   |
| 2. Dry Arcing Distance                   | 7.6" (193MM) MIN  |
| 3. Cantilever Strength                   | 1500lbs (6.7kN)   |
| 4. Low Frequency Flashover Voltage (Dry) | 95kV MIN          |
| 5. Low Frequency Flashover Voltage (Wet) | 65kV              |
| 6. Positive Critical Impulse Flashover   | 140kV             |
| 7. Radio Influence Voltage at 20kV       | 50 microvolts MAX |
| 8. Applicable Standard ANSI C29.7-1996.  |                   |

GENERAL TOLERANCE			DP57C-02 LINE POST INSULATOR (WITH "C" NECK)			
<30 mm	±1.5 mm	ANGLE:				
>30 mm	±5%					
Drawn	William Ma	Aug.17,2006	<b>DULHUNTY POWER</b>	Mass	Scale	
Verified	David Shao	Aug.17,2006		A4-6140	REV	C
Approved						